


Piloting low-tech Omni-processor


Support to the WWTP- receiving sludge

- Large volume of anoxic/anaerobic wastewater removed from sites every year (+450,000m3/year) and disposed of in overstretched WWTP:
 - Conventional treatment (aerobic | activated sludge)
 - Non or partially operational
 - Operation status has deteriorated with the current Energy crisis
 - Even if Innovative DEWATS is at scale in the country, sludge will still need to be removed from sites and safely managed



UNICEF LCO has been piloting the treatment performance of a LowTech Omniprocessor enabling receiving and treating the Wastewater and sludge from ISs desludging.







OMNIPROCESSOR ORIGINAL BLOC FLOW DIAGRAM 15 M3 Mass balance Mass balance BOD 500 mg/l BOD 1320 mg/l Flocculent COD 980 mg/l COD 2400 mg/l FOG 25,000 mg/l FOG 51000 mg/l TSS 2,400 mg/l TSS 16,000 mg/l Dried sludge Sludge dryer **Screw Press** Reception Area Raw sewage tank Solid waste manually Mass balance Mass balance removed / Manual bar screen BOD 225 mg/l BOD 200 mg/l Filtrate COD 460 mg/l COD 470 mg/l FOG 13,500 mg/l FOG 9700 mg/l TSS 1,300 mg/l TSS 900 mg/l Polishing filters Holding tank Disinfection **MBBR** Mass balance Mass balance Mass balance Mass balance Discharge BOD 50 mg/l BOD 60 mg/l BOD 180 mg/l BOD 170 mg/l COD 280 mg/l COD 290 mg/l COD 400 mg/l Backwash COD 400 mg/l FOG 1,300 mg/l FOG 1350 mg/l FOG 3400 mg/l FOG 2,500 mg/l TSS 350 mg/l TSS 600 mg/l TSS 350 mg/l TSS 600 mg/l **Irrigation Channel**

OMNIPROCESSOR ORIGINAL BLOC FLOW DIAGRAM













Mass balance BOD 170 mg/l COD 400 mg/l FOG 2,500 mg/l

TSS 350 mg/l


Channel



Challenges

- Energy Crisis leading to solarize the system
- Original treatment of the MBBR is affected by the low level of solid capture by the Flocculation and too high level of Fat Oil and grease
- Thus, UNICEF with the support of BMGF initiated an upgrade of the system, adding a Coagulation stage and DAF system as per the following scheme

OMNIPROCESSOR ACTUAL BLOC FLOW DIAGRAM





Proof of concept achieved

Treated Wastewater reach the ELVs for safe discharge in the environment. And reuse of biosolids is proven possible.

TREATE	ED INFLUENT	MEASI	IRED C	HARCT	HERIS	TICS AF	ETER TE	RTIAR	V TREAT	TEMEN	т			
TREATED INFLUENT MEASURED CHARCTHERISTICS AFTER TERTIARY TREATEMENT													Lebanese standards for	
														effluent Discharges
Parameters	Units	ts DAY1		DAY2		DAY3		DAY 4		DAY 5		DAY 6		
ρH	pH units	7.21	7.09	6.2	6.4	6.75	10.82	6.5	6.5	6.85	7.12	7.1	6.88	6-9
Biochemical Oxygen Demand	mg/L as O ₂	0.45	0.23	0.16	0.18	1.29	1.11	16.4	8.73	0.5	1.11	0.49	2.1	25
Chemical Oxygen Demand	mg/Las 02	2.5	1.2	0.8	1	5.2	1.9	22.7	15.2	1	1.8	1.9	5.1	125
Total Suspended Solids	mg/L	42	30	12	14.9	64	152	305	118	8970	35	80	67	G0
Ammonium	mg/LNH4	0.75	0.26	0.005	0.21	0.65	3.73	0.1	0.1	0.1	0.1	0.1	0.1	
Ammonium Nitrogen	mg/L NH4-N	0.58	0.2	0.005	0.16	0.5	2.9	0.1	0.1	0.1	0.1	0.1	0.1	10
Phosphate	mg/LP043-	0.05	0.02	0.002	0.002	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.02	10
Total Nitrogen	mg/L N	2,2	1.8	0,005	0.4	16	33.2	28.5	47.2	1.1	1.1	5	7.8	30
Salmonella	cfu/100 mL	0	0	0	0	0	0	28	32	0	0	0	0	0
Escherichia Coti	cfu/100 mL	0	0	0	0	0	0	84	42	0	0	0	0	0
Fecal Coliforms	cfu/100 mL	0	0	0	0	0	0	190	71	0	0	0	0	0
Mercury	ug/L	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	50
Cadmium	ug/L	0.09	0.15	0.05	0.1	0.01	0.09	0.05	0.08	0.04	0.08	0.05	0.05	200
Lead	ug/L	1.6	2.37	0.9	1.2	0.01	0.08	0.05	0.9	0.09	0.09	0.08	0.05	500
Arsenic	ug/L	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.01	100
Chromium	ug/L	0.25	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	2000
Copper	ug/L	3,29	5.12	2.1	0.88	0.09	1.8	1.01	2.14	1.8	1.2	4	3,44	500
Nickel	ug/L	2.77	3.65	0.06	0.54	0.14	1.65	1.8	1.04	1.1	2.1	4.1	2.8	500
Zinc	ug/L	0.46	2,05	0.09	0.07	0.25	0.28	0,9	0.09	0.09	0.1	0.22	0.8	5000
Titanium	ug/L	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	<5	

		Day 1	Day 2	Day 3	Day 4	Day 5	Day 6	ELVs (EPA 40 CFR	
Parameters	Units	Result	Result	Result	Result	Result	Result	503.12(e)(2))	
pH	pH units	7.5	7	6.9	7	7.2	7.12		
Moisture Content	%	15.1	8.2	12.8	10.21	9.54	12.1		
Bulk Density	g/cm ³	1.42	1.65	1.54	1.28	1.29	1.25		
Total Nitrogen	mg/Kg N	10220	4820	5000	4822	10500	10200		
Phosphate	mg/Kg PO ₄ 3-	2500	1522	1850	1500	1540	9000		
Conductivity	dS/m	0.69	0.62	0.671	0.55	0.612	0.623		
Fecal Coliforms	MPN/g dry weigl	<]	<]	<]	<]	<]	<]		
Salmonella	MPN/g dry weigl	<1	4	<]	1	<1	<1		
Escherichia Coli	MPN/g dry weigl	<]	<]	<]	<]	<]	<]		
Mercury	mg/Kg Hg	0.1	<0.01	<0.01	0.5	0.8	0.44	75	
Cadmium	mg/Kg Cd	0.5	0.22	1.2	1.45	1.81	3.17	85	
Lead	mg/Kg Pb	0.99	5.08	0.55	16.74	2.24	3.22	840	
Arsenic	mg/Kg As	10.2	2.1	1.1	20.9	21.5	15.4	75	
Chromium	mg/Kg Cr	101	72.3	17.3	12.79	11.34	33.63	85	
Copper	mg/Kg Cu	184.35	128.51	96.44	137.23	157.55	272.36	4,300	
Nickel	mg/Kg Ni	39.98	15.33	62.4	41.22	20.18	50.07	420	
Zinc	mg/Kg Zn	115.71	37.44	139.08	82.89	140.9	113.58	7,500	
Titanium	mg/Kg Ti	5.2	2.11	1.8	<]	2.1	<]		

Handover to the BWE

2.5



رقم الصادر : ١٤ ٢ / مرى التاريخ : ١٠ /٤ /٤٥ _ ٢

جانب منظمة UNICEF المحترمين

الموضوع: إستلام محطة Omni Processor والأشغال والمعدات الجديدة المنفذة والطاقة الشمسية ومولد كهربائي في محطة ايعات.

المرجع: - كتابكم المسجل لدى مصلحة الديوان في المؤمسة بالرقم ١٣٢ تاريخ ٢٠٢٤/١٠.

- إتفاقية هبة من جانب وزارة الطاقة والمياه بالرقم ٢٠٩٢ تاريخ ٢٠٢٠/٩/١٤.
- تقرير لجنة إستلام مشاريع تشغيل وصيانة شبكات ومحطات الصرف الصحي بتاريخ ٢٠٢٤/٤/٢٤
 - إحالة مصلحة المحطات والمشاريع بتاريخ ٢٠٢٤/٤/٢٥.

تبدي مؤمسة مياه البقاع موافقتها على إستلام محطة Omni Processor والأشغال والمعدات الجديدة المنفذة والطاقة الشمسية ومولد كهربائي في محطة ايعات وفق تقريري مصلحة المحطات والمشاريع ولجنة إستلام مشاريع تشغيل وصيانة شبكات ومحطات الصرف الصحي .

ريطاً: جدول بأسماء المكلفين بتشغيل المحطة




نسخ تبلغ:

- مصلحة المحطات والمشاريع
 - لجنة الإستلام




Opportunities

- To sustain the Operation and maintenance of the system with BWE having stretched financial and human resources UNICEF look how to develop a circular economy market to generate revenue from the biosolids produced.



Co-compost bags of 10kg - \$6/bag



Agricultural mix bags of 10kg - \$10/bag



United Nations COMTRADE database on international trade, Lebanon's imports of fertilizers were US\$28.52 Million in 2021.

LIBNOR stds (NL-ISO 19698:2020) reuse of biosolids.



Aarsal Road Map



Image – Wastewater leaking from the existing wastewater ponds in the Jurd of Aarsal

1.Context and background

1. Context and background

Demographics

- □ A town and the largest
 municipality in Baalbek district
 of BBH Governorate.
- ☐ High proportion of Syrian refugees living across 208 ITSs (approx. 32,000 population).
- ☐ Slightly less Syrian refugees living in residential areas (15,000).
- □ **40,000** Host Community.

Wastewater Context

- ❑ No network, reliant on desludging services.
- ☐ Currently **530m3/d** from ISs is discharged.
- ☐ High risk of groundwatercontamination to surroundingvillages.
- □ Governor of BBH collected **full consensus** from community for
 the UNICEF roadmap (2024).



Image – Ponds filled by wastewater in Aarsal (approx. 500m from households)

3. Medium to Long Term Solutions

3. Medium to long term solution



Installation of Fixed Bed BioReactor (FBBR) to enable treatment of 800m3/d of sludge.

m\$ 4.6 for the installation of the system including solarization and Composting plant



Rehabilitation of the open pond \$ 800,000 over 2 years



Operation and maintenance \$ 270,000 / year



Desludging Cost +m\$ 1/ year




Potential generation of income \$ 150,000/year Reuse of sludge as fertilizer \$ 50,000/year Reuse of treated water

Medium term Solution

m\$5.4 – Investment (system and rehabilitation)

m\$1.3 – Yearly operation cost (Desludging + O&M WWTP)

K\$ 200 – Yearly potential revenue generation



FBBR is a modular and scalable system enable to be connected to a network

X4 the number of modules + m\$ 7.5



Network would need to be in place – BTD estimate the cost at **m\$ 14** in its 2020 study.

Potential generation of income Up to \$ 600,000/year Reuse of sludge as fertilizer Up to \$ 200,000/year Reuse of treated water

Long term Solution

+m\$21.5 – Investment (system enlargement and network) m\$1.1 – Estimated yearly operation cost (O&M WWTP - tbc) K\$ 800 – Estimated yearly potential revenue generation



Discussion



For any question, please contact:

Kevin BONEL

WASH Specialist

kbonel@unicef.org

81 641 130

+33 6 08 65 88 36